

Sika (NZ) Ltd · PO Box 19192 · Avondale · Auckland 1746 · New Zealand

Brook Elgar
DryBase Tiled Showers
Unit 5, 44 Triton Ave,
Mt Maunganui
New Zealand

CONTACT

Andy Williams
Market Field Manager - Tiling
Phone: +64 9 820 2900
info@nz.sika.com

**SIKA TESTING OF DRYBASE WITH SIKA
WATERPROOFING OVER DRYBASE**

September 5, 2016

Sika (NZ) Ltd. Are happy to advise the we have tested the following products over the DryBase system.

Sikalastic-152
Sikalastic-200 W
Aquablok SBR
Aquablok 2 Part

Method

The DryBase is to be cleaned of all dust and contaminants. A primer is to be used as follows. Sikalastic- products are to have Sika Primer – 21 W used . The Aquablok products are the have Eco Prep & Prime used.

All of the systems mentioned above have good adhesion and show no signs of failure after being left for a minimum 30 days after final coat.

Sincerely,

Andy Williams

Market Field Manager - Tiling